



प्रतिभूति कागज कारखाना, नर्मदापुरम - 461005 (म.प्र.)

सिक्योरिटी प्रिंटिंग एंड मिंग्टिंग कॉर्पोरेशन ऑफ इंडिया लिमिटेड की इकाई (भारत सरकार के पूर्ण स्वामित्वाधीन)
मिनीरत्न श्रेणी-I सीपीएसई एवं आई.एस.ओ. 9001:2015, 14001:2015, 45001:2018, 50001:2018 एवं आईईसी 17025:2017 प्रमाणित



SECURITY PAPER MILL, NARMADAPURAM – 461005 (M P)

A Unit of Security Printing & Minting Corporation of India Limited (Wholly owned by Government of India)
Miniratna Category-I CPSE & ISO 9001:2015, 14001:2015, 45001:2018, 50001:2018 & IEC 17025:2017 Certified
CIN:U22213DL2006GOI144763, GSTIN: 23AAJCS6111J3ZE

Tel. No.: 07574-255259, E-mail: gm.spm@spmcil.com, Website: <http://spmarmadapuram.spmcil.com>

CORRIGENDUM-1

No. EO/Sludge filter beds/25-26/1402

Dated 08.05.2026

Ref.: EO/Sludge filter beds/25-26/1402

Against our above EO enquiry for (Upgradation and Renovation of Sludge Beds for Effluent treatment plant (ETP), New Effluent treatment plant (NETP) and Pulp treatment plant (PTP)) was published in the <http://spmarmadapuram.spmcil.com> on dated 20.03.2026. Further, to this Corrigendum-I as below is being issued to the tender enquiry with the following amendments:

Proposed amendments in technical specifications for better participation:

Specification Sr. No	Existing Tender Specification	Clarification & amendments/ To be read as
01	Bid opening date i.e. 21.04.2026 - 03:00 PM	19.05.2026 - 03:00 PM
A (g), B (g), C (g), D (g)	Providing FRP sheet and lifting of support for FRP sheet structure using suitable steel framework.	Frame Size: as per bed dimension (LxB) Material: Rust Proof material to bear the load of FRP sheet and sludge loading Note: Frame and FRP sheet are to be laid over bed supported on concrete columns.
A (j), B (j), C (j), D (j)	Site development: Bidder should construct RCC approach road and connect to the nearest road, Provide suitable arrangement for drain/rain water in the area. Suitable lighting Provision for working in night shifts near the filter bed.	RCC Approach Road: L- 110ft; W- 12ft; Thickness= 300mm Grade- fe-500D or more Steel size- 10mm; 200mm/c Drain/ Rain Water Arrangement: Open drain or pipeline need to be laid along road so passage of rain water. Lighting Arrangement: Quantity- 6nos i.e. 2 each for old bed, New Bed, PTP bed. Type: LED floodlight for outdoors 400lux

All other terms & condition of EO shall remain unchanged.

(बिप्लब बसाक) / (Biplab Basak)

प्रबंधक (सामग्री)-(प्रमुख)/Manager (Material)-Material Head

हेतु मुख्य महाप्रबंधक/ For- Chief General Manager